



Prüfzentrum für Bauelemente

Dipl.-Ing. (FH) Rüdiger Müller

Fenster • windows
Rollläden • shutters
Türen + Tore • doors
Fassaden • curtain walling
Baubeschläge • building hardware

TEST CERTIFICATE NO. 2021-27-0226-C3

Version 1.en

Applicant İşıldak İnşaat Taah. Tic.A.Ş.
Mutlukent Mah.1986 Sk. No:20
Ümitköy-Ankara-Türkiye

Test date March 25, 2021

Product name **Albert Genau Slider Next 10 All Glass**

Type Fully glazed sliding door with glazed panels made of 10 mm tempered glass (3 panels)

Dimension (W x H) max. 2400 mm x 2200 mm

Performance According to test report No. 2021-27-0226-B3 from April 28, 2021:

Air permability according to EN 12207 **Class 1**

Water Tightness according to EN 12208 **Class 2A**

Impact Resistance according to EN 14019 **Class I4/E4**

Measurement of deflection **+1600 Pa: 38,01 mm.**
According to EN 12211/12210 **-1600 Pa: 37,06 mm.**

Repeated pressure **+800 Pa / -800 Pa**
According to EN 12211/12210

Safety test **+2400 Pa / -2400 Pa**
According to EN 12211/12210

Validity Period of validity of standarts


Y. Altug
Technical Manager



April 28, 2021

