



Prüfzentrum für Bauelemente

Dipl.-Ing. (FH) Rüdiger Müller

Fenster • windows
Rollläden • shutters
Türen + Tore • doors
Fassaden • curtain walling
Baubeschläge • building hardware

TEST CERTIFICATE NO. 15/11-A002-C2

Version 1.en

Applicant

Işıldak İnşaat Taah. Tic.A.Ş.
Mutlukent Mah.1986 Sk. No:20
Ümitköy-Ankara-Türkiye

Test date

January 06, 2016

Product name

Albert Genau Tiara Twinmax

Type

Fully glazed sliding door with double glazed panels made of 4-20-4 mm glass as balcony glazing with stacking area, freely selectable number of glazed panels (3 panels), the first glazed panel opens on hinges.

Dimension

(W x H) max. 2400 mm x 2200 mm

Performance

According to test report No. 15/11-A002-B2 from February 02, 2016:

Air permability according to EN 12207 Class **3**

Water Tightness according to EN 12208 Class **2A**

Measurement of deflection
According to EN 12211/12210 (class 3) **+1200 Pa: 37,2 mm.**
-1200 Pa: 41,4 mm.

Repeated pressure
According to EN 12211/12210 (class 3) **+600 Pa / -600 Pa**

Safety test
According to EN 12211/12210 (class 3) **+1800 Pa / -1500 Pa**

Validity Period of validity of standarts

Y. Altuq
Technical Manager



February 02, 2016

PfB GmbH & Co. Prüfzentrum für Bauelemente KG
AG Traunstein HRA 8871
Lackermannweg 24, 83071 Stephanskirchen
phG PfB Verwaltungs GmbH
Geschäftsführer: Matthias Demmel, Rüdiger Müller
AG Traunstein HRB 16490

Telefon +49 (0) 80 36 / 67 49 47 0
Telefax +49 (0) 80 36 / 67 49 47 28
www.pfb-rosenheim.de
info@pfb-rosenheim.de

Sparkasse Rosenheim
Bankleitzahl 711 500 00
Kontonummer 500 556 741
Steuer-Nr.156/172/13009
USt-IdNr. DE245353602

